

140 WEST FLAGLER STREET, SUITE 1603 MIAMI, FLORIDA 33130-1563 (305) 375-2901 FAX (305) 375-2908

www.miamidade.gov

NOTICE OF ACCEPTANCE (NOA)

Folding Shutter Corporation 7089 Hemstreet Place West Palm Beach, Florida 33413

Scope:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: "Impact" Aluminum Bahama Shutter

APPROVAL DOCUMENT: Drawing No. 1018, titled "Impact Bahama Shutter (Dade)", sheets 1 through 10 of 10, prepared by W. W. Schaefer Engineering & Consulting, P.A., dated 12/08/2000, last revision #A1 dated 10/10/2005, signed & sealed by Warren W. Schaefer, P.E., bearing Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: Large and Small Missile Impact

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises & renews NOA # 01-0216.03 and consists of this page 1, evidence submitted page E-1 as well as approval document mentioned above.

Helm A. Melan 12/28/2006

The submitted documentation was reviewed by Helmy A. Makar, P.E., M.S.



NOA No 06-0831.02 Expiration Date: 11/15/2011 Approval Date: 12/28/2006

Page 1

Folding Shutter Corporation

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 01-0216.03

A. DRAWINGS

1. Drawing No. 1018, titled "Impact Bahama Shutter", prepared by W. W. Schaefer Engineering & Consulting, P.A., dated December 08, 2000, sheets 1 through 10 of 10, signed and sealed by Warren W. Schaefer, P.E. on October 22, 2001.

B. TESTS

1. Test Report on: 1) Large Missile Impact Test, per PA-201, 2) Cyclic Wind Pressure Test, per PA-203 and 3) Uniform Static Air Pressure test per PA-202, of Bahama shutters, prepared by Hurricane Test Laboratory Inc., Report Nos. 0143-0912-00, 0143-0713-00, and 0143-0108-01 dated February 13, 2001, signed and sealed by Vinu J. Abraham, P.E.

C. CALCULATIONS

1. Anchor analysis and calculations dated 02/08/2001, Pages 1 to 51, prepared by W. W. Schaefer Engineering & Consulting, P.A., signed and sealed by Warren W. Schaefer, P.E. on 02/08/2001.

D. MATERIAL CERTIFICATION

1. Certified Tensile Test Report No. 1BM-186, prepared by QC Metallurgical Inc., dated 05/24/2001, signed and sealed by Frank Grate, P.E.

2. NEW EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. 1018, titled "Impact Bahama Shutter (Dade)", sheets 1 through 10 of 10, prepared by W. W. Schaefer Engineering & Consulting, P.A., dated 12/08/2000, last revision #A1 dated 10/10/2005, signed & sealed by Warren W. Schaefer, P.E.

B. TESTS

1. None.

C. CALCULATIONS

1. Anchor analysis and calculations dated 10/10/2005, 17 Pages, prepared by W. W. Schaefer Engineering & Consulting, P.A., signed and sealed by Warren W. Schaefer, P.E. on 10/10/2005.

D. QUALITY ASSURANCE


1. By Miami-Dade County Building Code Compliance Office.


E. MATERIAL CERTIFICATIONS


1. None.


Helmy A. Makar, P. E., M.S. Product Control Examiner NOA No 06-0831.02


Expiration Date: 11/15/2011 Approval Date: 12/28/2006























	PRESSURE	LOAD T	ABLE F	OR STOR	RM BARS	& BAR EN	ID CONN	ECTIONS	
SHUTTER WIDTH	BAR SPACING		LE PRESSI TROLLED I	JRE (PSF) BY BARS	ALLOWABLE PRESSURE (PSF) AS CONTROLLED BY BAR END CONNECTIONS				
(IN)	(IN)	3" BAR	4" BAR	5" BAR	11	"A" & "B"		NN "C"	CONN "D"
					WOOD	BLOCK/CONC	WOOD	BLOCK/CONC	BLOCK/CONC
30	36	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0
30	42	80.0	80.0	80.0	80.0	72.4	80.0	80.0	80.0
	48	80.0	80.0	80.0	80.0	63.4	80.0	80.0	80.0
36	30	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0
	36	80.0	80.0	80.0	80.0	70.4	80.0	80.0	80.0
	42	80.0	80.0	80.0	80.0	60.3	80.0	80.0	80.0
	48	80.0	80.0	80.0	80.0	52.8	80.0	80.0	80.0
	24	80.0	80.0	80.0	80.0	80.0	80.0	80.0	80.0
	30	80.0	80.0	80.0	80.0	72.4	80.0	80.0	80.0
42	36	80.0	80.0	80.0	80.0	60.3	80.0	80.0	80.0
	42	80.0	80.0	80.0	80.0	51.7	80.0	80.0	80.0
	48	80.0	80.0	80.0	79.9	45.3	80.0	80.0	80.0
	24	80.0	80.0	80.0	80.0	79.2	80.0	80.0	80.0
	30	80.0	80.0	80.0	80.0	63.4	80.0	0.08	80.0
48	36	80.0	80.0	80.0	80.0	52.8	80.0	80.0	80.0
1 70	42	80.0	80.0	80.0	79.9	45.3	80.0	80.0	80.0
	48	80.0	80.0	80.0	69.9	39.6	80.0	0.08	80.0
	24	80.0	80.0	80.0	80.0	70.4	80.0	80.0	80.0
	30	80.0	80.0	80.0	80.0	56.3	80.0	80.0	80.0
54	36	80.0	80.0	80.0	80.0	46.9	80.0	80.0	80.0
	42	80.0	80.0	80.0	71.0	40.2	80.0	80.0	80.0
	48	80.0	80.0	80.0	62.1	35.2	80.0	72.9	80.0
	24	80.0	80.0	80.0	80.0	63.4	80.0	80.0	80.0
	30	80.0	80.0	80.0	80.0	50.7	80.0	80.0	80.0
60	36	80.0	80.0	80.0	74.6	42.2	80.0	80.0	80.0
	42	77.5	80.0	80.0	62.4	35.4	80.0	73.2	80.0
	48	69.4	80.0	0.08	55.9	31.7	88.4	65.6	80.0
	24	80.0	80.0	80.0	80.0	57.6	0.08	80.0	0.08
	30	0.08	80.0	0.08	80.0	46.1	80.0	80.0	80.0
66	36	78.5	80.0	80.0	67.8	38.4	80.0	79.5	80.0
	42	67.3	0.08	0.08	58.1	32.9	80.0	68.2	0.08
	48	58.9	80.0	80.0	50.8	28.8	80.4	59.6	80.0
	24	80.0	80.0	80.0	80.0	52.8	80.0	80.0	80.0
	30	80.0	80.0	0.08	74.6	42.2	0.08	80.0	80.0
72	36	67.4	80.0	80.0	62.1	35.2	80.0	72.9	0.08
	42	57.8	80.0	80.0	53.3	30.2	80.0	62.5	80.0
	48	50.6	80.0	0.08	46.6	26.4	73.7	54.7	0.08
	24	80.0	80.0	80.0	80.0	48.7	80.0	80.0	80.0
	30	70.2	80.0	80.0	68.8	39.0	0.08	80.0	80.0
78	36	58.5	80.0	80.0	57.4	32.5	80.0	67.3	80.0
	42	50.2	80.0	80.0	49.2	27.9	77.7	57.7	80.0
<u> </u>	48	43.9	70.9	80.0	43.0	24.4	68.0	50.5	75.8
84	24	77.0	0.08	80.0	79.9	45.3	80.0	80.0	80.0
	30	61.6	0.08	80.0	63.9	36.2	80.0	75.0	80.0
	36	51.3	80.0	80.0	53.3	30.2	0.08	62.5	80.0
	42	44.0	71.0	80.0	45.6	25.9	72.2	53.6	80.0
	48	38.5	62.1	0.08	39.9	22.6	63.1	46.9	70.4

PRESSURE LOAD TABLE FOR STORM BARS & BAR END CONNECTIONS									
SHUTTER WIDTH	HEIGHT OR BAR SPACING (IN)	ALLOWABLE PRESSURE (PSF) AS CONTROLLED BY BARS			AS CONTROLLED BY BAR END CONNECTIONS				
(IN)		3" BAR	4" BAR	5" BAR	CONN "A" & "B"		CONN "C"		CONN "D"
					WOOD	BLOCK/CONC	WOOD	BLOCK/CONC	BLOCK/CONC
90	24	53.4	80.0	80.0	74.6	42.2	80.0	80.0	80.0
	30	42.7	80.0	80.0	59.6	33.8	80.0	70.0	80.0
	36	35.6	73.2	80.0	49.7	28.2	78.6	58.3	80.0
	42	30.5	62.7	80.0	42.6	24.1	67.4	50.0	75.1
	48	26.7	54.9	77.2	37.3	21.1	58.9	43.7	65.7
96	24	42.3	80.0	80.0	69.9	39.6	80.0	80.0	80.0
	30	33.8	71.2	80.0	55.9	31.7	80.0	65.6	80.0
	36	28.2	59.4	80.0	46.6	26.4	73.7	54.7	80.0
	42	24.1	50.9	78.6	39.9	22.6	63.1	46.9	70.4
	48	21.1	44.5	68.7	35.0	19.8	55.3	41.0	61.6
102	24	_	71.4	80.0	65.8	37.3	80.0	77.2	80.0
	30	-	57.1	80.0	52.6	29.8	80.0	61.7	80.0
	36	_	47.6	80.0	43.9	24.8	69.3	51.5	77.3
	42	_	40.8	70.4	37.6	21.3	59.4	44.1	66.3
	48	_	35.7	61.6	32.9	18.6	52.0	38.6	58.0
108	24		58.0	80.0	62.1	35.2	80.0	72.9	80.0
	30	_	46.4	80.0	49.7	28.2	78.6	58.3	80.0
	36	-	38.7	68.2	41.4	23.5	65.5	48.6	73.0
	42	_	33.1	58.4	35.5	20.1	56.1	41.7	62.6
	48	-	29.0	51.1	31.1	17.6	49.1	36.4	54.8
112	24		50.7	80.0	59.9	33.9	80.0	70.3	80.0
	30		40.6	71.6	47.9	27.2	75.8	56.2	80.0
	36	-	33.8	59.7	39.9	22.6	63.1	46.9	70.4
	42	- 1	29.0	51.1	34.2	19.4	54.1	40.2	60.3
	48		25.4	44.7	30.0	17.0	47.4	35.1	52.8

1. ALL PRESSURES ARE FOR BOTH POSITIVE & NEGATIVE AND ARE PSF.

2. REF. SHEET 7 FOR CONNECTION TYPES & DETAILS.

LOAD TABLE INSTRUCTIONS:

- 1. SELECT AN OVERALL SHUTTER SIZE (TOTAL WIDTH & HEIGHT).
- 2. DETERMINE THE REQUIRED DESIGN WIND PRESSURE FOR THE SHUTTER.
- 3. IF THE SHUTTER HEIGHT IS LESS THAN OR EQUAL TO 76", GO TO "PRESSURE TABLE FOR SINGLE SPAN SHUTTERS" ON SHEET 9 AND COMPARE THE REQUIRED DESIGN PRESSURE TO THE ALLOWABLE PRESSURES IN THE TABLE. IF ALLOWABLE PRESSURE IS EQUAL TO OR GREATER THAN THAT REQUIRED, NO BAR IS REQUIRED & YOU ARE FINISHED. IF ALLOWABLE PRESSURE IS LESS THAN REQUIRED, STORM BAR(S) ARE NEEDED, SO CONTINUE TO NUMBER 4 BELOW.
- 4. IF BARS ARE REQUIRED, GO TO LOAD TABLES ON THIS SHEET.
- 5. GO TO APPLICABLE SHUTTER WIDTH IN TABLE AND CHOOSE THE DESIRED BAR SPACING.
- 6. GO ACROSS THE TABLE AND CHOOSE THE BAR AND CONNECTION WHO'S ALLOWABLE PRESSURE
- IS GREATER THAN OR EQUAL TO THE REQUIRED PRESSURE. IF THE DESIRED BAR AND/OR CONNECTION TYPE DOES NOT MEET THE REQUIRED SHUTTER DESIGN PRESSURE, CHOOSE ANOTHER BAR SPACING AND CHECK THE BAR TYPE & CONNECTION AGAIN. REPEAT UNTIL DESIRED & CORRECT BAR & CONNECTION TYPE ARE DETERMINED (NOTE THAT THE LESSER PRESSURE OF THE BAR, CONNECTION TYPE,
- OR MAXIMUM ALLOWABLE OF ± -80 PSF SHALL CONTROL THE SHUTTER).

PRODUCT REVISED
as complying with the Florida
Baiding Cods
Acceptance No 06 - 083/ • 6
Expiration Date II / 15/12 9 1

By Helen Daded Theres Control

CONSULTANTS

W. W. SCHAEFER ENGINEERIN
& CONSULTING, P.A.
8885 MILLIFOR TRAIL. SUITE C-204
PAIN REAL CARRIES ENTER C-204

(DADE)

SHUTTER

DATE: 12/08/00

CERTIFICATION

SOHAEFER, P.E.

DRAWING NO. REV 1018 A SHEET NO. 10 OF 10